

---

---

## Addendum #6

Date: 3/21/2019

Project: MILWAUKEE PUBLIC LIBRARY GOOD HOPE MILL ROAD

Proj. #: 170044.00

From: Zimmerman Architectural Studios, Inc.


To: Furniture Manufacturer

This Addendum is issued to modify, explain, and amend the originally issued Specifications and Drawings dated 3/8/2019 and is hereby made a part of the Contract Documents. Please acknowledge receipt of this Addendum.


### PLEASE INSERT THIS ADDENDUM IN THE DOCUMENT SET

BID PACKAGE #4 – TEKNION

WR-3 – Updated dimensions



WR-2 – Updated dimensions



WR-2 is calling out for a 30x48 and a 24x72, but the WR-3 is calling out for a 30x72 and a 24x48 – could you please confirm that is how you would like it or if I need to make the WR-3 a 30x48 and a 24x72 please?

**ZAS CLARIFICATION:** WR-2 and WR-3 should be 30"x66" at the main work surface, and the entire return side should span 72" as it spans below the main work surface top. The return side itself is 48" long on WR-3 and 42" on WR-2 (verify in field) with a 30" lateral file below. WR-2 receives the bench with cushion on top in addition to this.

- End of Addendum #6

